

Certificate of Product Approval

Certificate Number: 1153Le

Issue: 01

Tianjin Pro Made Fire Equipment Company Limited

25th Floor 2nd Tower
Beichen Building
Beichen District
Tianjin
China



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

'TPMC' Wet Landing Valves

(Refer to attached appendix for details)

Standards

BS 5041-1:1987

Fire hydrant systems equipment. Specification for landing valves for wet risers

This certificate and appendix is maintained and held in force through regular surveillance activities

S.A. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

10 April 2019

Date of Issue

10 April 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1153Le Tianjin Pro Made Fire Equipment Company Limited

Issue: 01

'TPMC' Wet Landing Valves to BS 5041-1:1987

Product Name	Description	LPCB Ref. No.
F21-50	DN50, oblique type, low pressure, flanged inlet, globe valve	1153Le/01
F21-65	DN65, oblique type, low pressure, flanged inlet, globe valve	1153Le/02
F22-65P	2 ½", oblique type, low pressure, BSP female threaded inlet, globe valve	1153Le/03
F22-65T	2 ½", oblique type, low pressure BSPT male threaded inlet, globe valve	1153Le/04
F25-50	DN50, right angle type, low pressure, flanged inlet, globe valve	1153Le/05
F25-65	DN65, right angle type, low pressure, flanged inlet, globe valve	1153Le/06
F26-65T	2 ½", right angle type, low pressure, BSPT male threaded inlet, globe valve	1153Le/07
F24-65T	2 ½", horizontal type, low pressure, BSPT male threaded inlet, globe valve	1153Le/08
F23-50	DN50, horizontal type, low pressure, flanged inlet, globe valve	1153Le/09
F23-65	DN65, horizontal type, low pressure, flanged inlet, globe valve	1153Le/10
F28-65T	2 ½", bib nosed type, low pressure, BSPT male threaded inlet, globe valve	1153Le/11
F27-50	DN50, bib nosed type, low pressure, flanged inlet, globe valve	1153Le/12
F27-65	DN65, bib nosed type, low pressure, flanged inlet, globe valve	1153Le/13
F29-50	DN50, bib nosed type, high pressure, flanged inlet, globe valve	1153Le/14
F29-65	DN65, bib nosed type, high pressure, flanged inlet, globe valve	1153Le/15
F30-65T	2 ½", bib nosed type, high pressure, BSPT male threaded inlet, globe valve	1153Le/16

Notes:

1. The maximum working pressure is 15 bar for low pressure landing valves
2. The maximum working pressure is 20 bar for high pressure landing valves

This certificate and appendix is maintained and held in force through regular surveillance activities

S.A.C. Colwell

Signed for BRE Global Ltd.

Sarah Colwell

Verifier

10 April 2019

Date of Issue

10 April 2019

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre