

Certificate of Compliance

Certificate Number:

[EX28526]

Report Reference:

EX28526-20210108

Issue Date:

2024-NOV-06

Issued to:

TIANJIN PRO MADE FIRE EQUIPMENT COMPANY LIMITED
Room 1103, Zhengrong Technology Building 1, Hongqiao,
TIANJIN 300131, CHINA

This certificate confirms that representative samples of:

METALLIC SPRINKLER PIPE
See Addendum page for models

Has been evaluated by UL LLC in accordance with Standard(s) for Safety:

[UL 852 - UL Standard for Safety for Metallic Sprinkler Pipe for Fire Protection Service
ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler Systems For Fire Protection Service.]

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Picuch
UL Mark Certification Program Owner



Certificate of Compliance

Certificate Number: EX28526
Report Reference: EX28526-20210108
Issue Date: 2024-NOV-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models:

Schedule 40 (black or galvanized) seamless steel pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12 and 14 in. sizes as per ASTM A53/A53M, Grade B, Type S.

Schedule 80 (black or galvanized) seamless steel pipe in the 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6 and 8 in. sizes as per ASTM A53/A53M, Grade B, Type S.

