


Intelligent maintained running man exit sign (Plastic enclosure)

Intelligent maintained running man exit sign (Plastic enclosure) integrates with a central monitoring system via its built-in networking interface, which is a continuously illuminated evacuation device installed above exit doors and along egress paths. It provides clear guidance to emergency exit, ensuring high visibility and reliable direction for occupant in low-light or smoke-obscured environments.



- Certificate: UL Listed
- Standard: UL 924, NFPA 70, NFPA 101, IBC
- Feature: High brightness, addressable
- Temperature: -5°C to 45°C
- Installation: Ceiling or wall, surface mounting
- Location: Indoors only, IP20



Main parts and material

| | | | |
|---------------------|---|---------------------|--|
| Enclosure | Fire retardant ABS (UL 94 V-0 rated) | Light source | LED array, up to 100 ft viewing distance |
| Backup power | Built-in rechargeable battery, 24 hours charge time, overcharge and over-discharge protection | Networking | RS485 |
| Accessories | Universal mounting bracket (fits standard junction box) | Others | Manual test button, status indicator |

Available size

| Type | Main power | Backup power | Duration | Luminance | Dimension W x H x D (mm) | Ref. No. |
|---|--|-----------------------|----------|------------------------|--------------------------|-------------|
| Single face, running man | 120/277 VAC, 50/60 Hz, consumption 3.5 W | Ni-MH, 4.8 V, 600 mAh | 3 hours | > 10 cd/m ² | 330 x 190 x 63 | CL3401 (UL) |
| Single face, running man + arrow to right | 120/277 VAC, 50/60 Hz, consumption 3.5 W | Ni-MH, 4.8 V, 600 mAh | 3 hours | > 10 cd/m ² | 330 x 190 x 63 | CL3402 (UL) |
| Single face, running man + arrow to left | 120/277 VAC, 50/60 Hz, consumption 3.5 W | Ni-MH, 4.8 V, 600 mAh | 3 hours | > 10 cd/m ² | 330 x 190 x 63 | CL3403 (UL) |
| Single face, running man + arrow to down | 120/277 VAC, 50/60 Hz, consumption 3.5 W | Ni-MH, 4.8 V, 600 mAh | 3 hours | > 10 cd/m ² | 330 x 190 x 63 | CL3404 (UL) |